



MEMORANDUM

DATE: February 27, 2007

TO: Water Quality Management Committee

FROM: Richard Muzzy, PPACG

SUBJECT: Site Application for Platte Canyon School District Wastewater Treatment Plant

On February 6, 2007 the Site Application Review Committee (SARC) reviewed the site application for the Platte Canyon School District WWTF. The SARC members agreed that the site application was contingent upon the following items:

- Describe discrepancy between the PELs that were issued based on 10,000 gallons per day and the site application permit which is for 14,000 gallons per day. This should include a discussion regarding the possibility of different limits.
- Describe how the 14,000 gallons per day average daily flow was calculated.
- Discussion regarding any chemicals generated by high school lab.
- Clarification and discussion regarding lining of lagoon Pond 2.
- Warranty deed and proof of site ownership of where the WWTF will be located.
- Typographical errors in report: Amount shown as contingencies is shown as \$5,000 (pg V-4); and clarification that effluent will be delivered through a pipeline (bottom of pg V-1)
- Copy of page 9 of 14 for PELs.

Responses to the comments made at the SARC meeting and copies of the pertinent information from the site application are enclosed.

ACTION REQUESTED: Review and Approve